

DECLARATION OF CONFORMITY

No. 04/2024

1. Product Name:

Mixing unit with pump

2. Product Marking:

Mixing unit with pump

3. Intended Use:

Mixing units are installed in water systems to protect the system against excessive temperature.

4. Manufacturer:

Wigell Sp. z o.o. Michałowicza 12, 43-300 Bielsko-Biała, Poland

5. Product Characteristics:

- Electronic circulation pump
- Automatic air vent valve
- Manual air vent valve
- Thermostatic valve
- Thermometer
- Installation connectors

Operating temperature range: 10 ÷ 70°C, maximum pressure depending on the system, up to 0.6 MPa.

6. Country of origin: Poland (PL)

The products listed in this declaration comply with the relevant requirements of EU harmonized legislation PED 2014/68/EU and, in accordance with Article 4(3), good engineering practice, they are not CE marked.

7. The units were manufactured in accordance with the referenced standards:

- PN-M-75002:2016-10 Water supply and central heating installation fittings – Requirements and testing
- PN-EN 1254-4:2021-10 Installation connectors
- PN-EN 13190:2004 Dial thermometers

Dariusz Kasik

CEO



(signature)

Strumień, 18.01.2024

(place and date of issue)

.PL
Wigell Sp. z o.o.
ul. Michałowicza 12
43-300 Bielsko-Biała
Poland
PL5272747017

.CZ
Wigell s.r.o.
Mariánské náměstí 617/1
617 00 Brno
Czech Republic
CZ14317150

.SK
Wigell s.r.o.
Partizánska 78/42
962 12 Detva
Slovakia
SK2121093194


WIGELL
www.wigell-group.com